
NOTES:
1. PIPE LINE #'S CORRESPOND TO THE ORIGINAL PIPE LINE #'S. USED ON DWGS. E-19296, E-19297, E-19298, E-19413 UNLESS NOTED OTHERWISE.
2. THE LAST INSTRUMENT AIR LINE NUMBER USED ON THIS DWG. IS 223.
3. LINE NO'S AVAILABLE FOR INSTRUMENT AIR 224-234.
DWG. NO./CAD FILE CROSS REFERENCE
DRAWING NO. | CAD FILE NO.
D-40008 | LEADSHTM.DWG
D-40219 | PI069288.DWG
D-40221 | PI069270.DWG
D-40232 | PI069281.DWG
D-40241 | PI069290.DWG
D-40427 | PI069476.DWG
D-40537 | PI069556.DWG
D-40570 | PI069819.DWG
LEGEND:
F.O. = FAIL OPEN
F.L. = FAIL LAST POSITION
F.I. = FAIL INDETERMINATE
F.C. = FAIL CLOSED
ELECTRICAL
PNEUMATIC LINE
PLUG VALVE
GATE VALVE
3-WAY VALVE
REDUCER
UNION
BALL VALVE
CAP
DIAPHRAGM VALVE
PLUG
PISTON ACTUATOR
DIAPHRAGM ACTUATOR
SOLENOID ACTUATOR
PRESS. RELIEF VALVE
PLUG VALVE
TRAP
PUMP
MOTOR
INSTRUMENT SYMBOLOGY:
LOCAL
PANEL FRONT (LOCAL)
PANEL REAR (LOCAL)
PANEL FRONT (CONTROL ROOM)
PANEL REAR (CONTROL ROOM)
INSULATION
SIGHT GLASS
ANGLE VALVE
CLEANING BALL
CHECK VALVE
LIGHT FIXTURE
AGITATOR
CONTROL VALVE W/ I/P TRANSDUCER & POSITIONER
REV | DATE | GRID | DESCRIPTION | PROJ | BY | CHK | APP
2 | 11-10-95 | REVISED PER ENGINEERING COMMENTS | WO'C
1 | 2-3-95 | REVISED PER ENGINEERING COMMENTS | WO'C
0 | 2-1-95 | DRAWING APPROVED | WO'C
PIPING AND INSTRUMENTATION DIAGRAM
BLENDING TANK TA-300
PU-302
DESCRIPTION: TRANSFER PUMP
I.D. NO. MOC'A'
CAPACITY:
MFG./MODEL/SIZE: TRI CLOVER SP
TYPE OF SEAL:
MOTOR DATA:RELIANCE TYPE P,3510 RPM, 7.5 HP
MAT'L OF CONSTR.: 213T FRAME
TA-300
DESCRIPTION: BLENDING TANK (W/ COIL)
ID NO: E-49987
OPER. PRESS.: 30 PSI MAX.
SIZE: 250 GAL.
DESIGN VACUUM PRESS.: 30 PSI (MAX)
DESIGN TEMP. 274 °F
MAT'L OF CONSTRUCTION: STN. STL.
EQUIP. FINISH:
AG-301
DESCRIPTION: AGITATOR
ID. No.
HP/RPM
TYPE/DIA IMPELLER
TYPE OF SEALS
MAT'L OF CONSTRUCTION
MOTOR DATA
TA-300
AG-301
PU-302
EMERGENCY STOP
CHILLED WATER
WASH MANIFOLD
WASH HEADER
WASH MANIFOLD BEHIND TA-300
LABELED #13
LABELED #12
LITE
SET @ 30 PSI
SET @ 20 PSI
P1069269.DWG
File: H:\DPS\CHECKOUT\PI069269.DWG Last edited: MAR. 27, 01 @ 08:45 a.m. by: Requeram