

Remaining Life--Jacket

ATTN J. Lassette

Pressure Vessel Inspection Report

National Board Inspection Code Requirement

Section RB-3235

Merck Designation
54RE214

I-Number
61932

Equip No.
[REDACTED]

Remaining Life and Inspection Interval Calculations

Remaining Life Calculation

$$\text{Remaining Life (years)} = \frac{\text{Actual Thickness} - \text{Required Thickness}}{\text{Corrosion Rate}}$$

$$\text{Corrosion Rate} = \frac{\text{Original thickness} - \text{Actual thickness}}{\text{Years in Service}}$$

$$\text{Corrosion Rate} = \frac{0.422 - 0.211}{16}$$


$$\text{Remaining Life (years)} = \frac{0.211 - 0.2452}{0.013175}$$

Remaining Life (years) = UNSATISFACTORY, BELOW MINIMUM THICKNESS FOR DESIGN PRESSURE

Summary and Conclusion

Additional areas of the jacket on the north side were measured for thickness around the .211 reading for verification. The current safety valve set pressure of 75 psi is below the calculated allowable working pressure of 77 psi. The jacket is safe for operation for the brine and tower water service. The thickness readings should be taken again during shut down next year, and if warranted an internal (boroscope) inspection of the jacket is advisable to determine the actual condition for evaluation of possible repair.

Signed



Lyle Phelps,
Chief Mechanical Inspector

National Board Commission
N. J. Certification of Competency

OU798
1030

Date 9/29/2004

11/2/07 12:69

SA 60 - 1000 Gallons
 FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

617-13

1. Manufactured and certified by De Dietrich, 1 rue d'Offwiller, 67110 Zinswiller, France
 (Name and address of manufacturer)

2. Manufactured for _____
 (Name and address of purchaser)

3. Location of installation Merck & Company, Inc. Rahway, New Jersey
 (Name and address)

4. Type Vertical 33044 N/A SA 1000 A 3975 1986
 (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME Boiler and Pressure Vessel Code. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1985
 (Year)

6. Heads: (a) Material SA 285 B (b) Material N/A
 (Mark as per U-1) (Mark as per U-1)

7. Seams: Welded, Dbl. Butt Spot 85 N/A
 (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Mark as per U-1)

8. Heads: (a) Material N/A (b) Material N/A
 (Mark as per U-1) (Mark as per U-1)

Rows 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, or sheets of heat exchangers

6. Shell: SA 285 B 27/64" N/A 5 ft. 6-15/16" O.D. 6 ft. 1/8"
 (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Length (Outside) & in)

7. Seams: Welded, Dbl. Butt Spot 85 N/A
 (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Mark as per U-1)

8. Heads: (a) Material SA 285 B (b) Material N/A
 (Mark as per U-1) (Mark as per U-1)

Location (Top, Bottom, End)	Minimum Thickness	Corrosion Allowance	Corrosion Radius	Stanchion Radius	Height of Stanchion	Angle of Apex Angle	Manufactured Radius	Flange Diameter	Notes to Pressure (Nature of Contents)
(a) Bottom	15/32"	N/A	66-15/16"	6-11/16"	N/A	N/A	N/A	N/A	Concave
(b)					N/A				

If removable, both used (describe other fastenings) _____
 (Mark as per U-1) (Mark as per U-1)

9. Type of Jacket TYPE 2, PER FIG. 9.2 (Mark as per U-1)

10. Jacket Closure FIG. 9.5 (b-2) & 9.6 (a-1) (Mark as per U-1)

11. MAWP 90 or 90 & P.V. psi at max. temp. 200 °F. Max. temp. (when less than -20° F) N/A
 (Mark as per U-1) (Mark as per U-1) (Mark as per U-1)

12. Hydro. Press. 120 psi (Mark as per U-1)

13. If removable, both used (describe other fastenings) _____
 (Mark as per U-1) (Mark as per U-1)

14. Shell: SA 285 B 45/64" N/A 5 ft. 3" O.D. 5 ft. 4-7/16"
 (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Length (Outside) & in)

15. Seams: Welded, Dbl. Butt Spot 85 N/A
 (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Mark as per U-1)

16. Heads: (a) Material SA 285 B (b) Material SA 285 B
 (Mark as per U-1) (Mark as per U-1)

Rows 14-17 incl. to be completed for inner chambers of jacketed vessels or chambers of heat exchangers

14. Shell: SA 285 B 45/64" N/A 5 ft. 3" O.D. 5 ft. 4-7/16"
 (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Length (Outside) & in)

15. Seams: Welded, Dbl. Butt Spot 85 N/A
 (Mark as per U-1) (Mark as per U-1) (Mark as per U-1) (Mark as per U-1)

16. Heads: (a) Material SA 285 B (b) Material SA 285 B
 (Mark as per U-1) (Mark as per U-1)

Location (Top, Bottom, End)	Minimum Thickness	Corrosion Allowance	Corrosion Radius	Stanchion Radius	Height of Stanchion	Angle of Apex Angle	Manufactured Radius	Flange Diameter	Notes to Pressure (Nature of Contents)
(a) Top	25/32"	N/A	50-3/8"	0-3/8"	N/A	N/A	N/A	N/A	Concave
(b) Bottom	25/32"	N/A	50-3/8"	0-3/8"	N/A	N/A	N/A	N/A	Both

If removable, both used (describe other fastenings) _____
 (Mark as per U-1) (Mark as per U-1)

17. MAWP 100 & P.V. psi at max. temp. 200 °F. Max. temp. (when less than -20° F) N/A
 (Mark as per U-1) (Mark as per U-1) (Mark as per U-1)

18. Hydro. Press. 120 psi (Mark as per U-1)

19. If removable, both used (describe other fastenings) _____
 (Mark as per U-1) (Mark as per U-1)

This form (U-100) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

P.O. #Y062506A

SA 60 - 1000 Gallons

FORM U-4 MANUFACTURER'S DATA REPORT SUPPLEMENTARY SHEET
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

2.3

1. Manufactured and certified by De Dietrich, 1 rue d'Offwiller, 67110 Zinswiller, France
(Name and address of manufacturer)

2. Manufactured for _____
(Name and address of purchaser)

3. Location of installation Merck & Company, Inc. Rahway, New Jersey
(Name and address)

4. Type Vertical 33044 N/A SA 1000 A 3973 1985
(Mark, cert., spec., etc.) (Design serial No.) (CRN) (Code) (Unit No.) (Year built)

Data Report Item Number	Remarks
20 Remarks	<p><u>*Vessel H.T. at high temperature for extended period of time due to glass lining process.</u></p> <p><u>30" dia. inlet cover contains one 14" x 18" dia. oval manhole (with cover containing 4" dia. sight glass) one 4-3/8" dia. nozzle and two 2" dia. nozzles.</u></p> <p><u>inner vessel design pressure of 100 psig and F.V. at 650°F is limited to 500°F max. allowable working temperature due to glass lining process.</u></p> <p><u>Safety relief valve to be supplied by customer.</u></p> <p><u>Glass lined steel vessel for chemical use.</u></p>

Date May 12, 1986 Co. name De Dietrich Signed Walter D. O.C. Harlow

Date May 15, 1986 Signed Martin KOENIG Commission N.R. 0394

429.361 P.O. #Y062506A

This form (B09118) is available from the Order Dept., ASME, 345 E. 47 St., New York, N.Y.

Form U-1 (Back)

18. Nozzles, Inspection and Safety Valve Openings:

Purpose (Label, Order, Draw, etc.)	No.	Dim or Size	Type	Matl	Spec Thk	Reinforce Matl	How Attached	Location
Inlet	1	30"	Dbl. Butt BIRTH	SA 181-60	25/32"	None	Welded	on top head
Manhole	1	14"x18"	Dbl. Butt Girth	SA 181-60	25/32"	None	Welded	on cover
Inlet	1	8"	Dbl. Butt Girth	SA 181-60	5/8"	None	Welded	N/A
Inlet	4	4"	Dbl. Butt Girth	SA 181-60	5/8"	None	Welded	N/A
Outlet	1	4"	Dbl. Butt Girth	SA 181-60	5/8"	None	Welded	shell/head
Jacket	2	5-3/4"	Sit through	SA 516-60	2-1/8"	None	Welded	N/A
Jacket	2	3"	Sit through	SA 105	Standard	None	Welded	N/A
Jacket	2	2"	Sit through	SA 105	Standard	None	Welded	N/A
Jacket	6	1-1/2"	Sit through	SA 105	Standard	None	Welded	N/A
Jacket	1	3/4"	Sit on	SA 105	Standard	None	Welded	N/A
Jacket	1	1/2"	Sit through	SA 105	Standard	None	Welded	N/A
19. Supports: Skirt				NO Lug	Lug	Other	Attached	
				(Yes or no)	(No)	(No)	(Where and how)	

20. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: N/A

see attached form U-4

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

"U" Certificate of Authorization No. 11718 expires April 15, 1986
 Date May 12, 1986 Co. name De Dietrich Signed WAGNER R. O.C. Hanson

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by De Dietrich at Zimmiller, France
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of New York and employed by The Royal Indemnity Company

of New York, N.Y. have inspected the pressure vessel described in this Manufacturer's Data Report on April 29, 1986 and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the vessel described in the Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage of a loss of any kind arising from or connected with this inspection.

Date May 15, 1986 Signed Martin KOENIG Commission No. N.B. 9354

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the field assembly construction of all parts of the vessel conforms with the requirements of Section VIII, Division 1 of the ASME Boiler and Pressure Vessel Code.

"U" Certificate of Authorization No. _____ expires _____, 19____
 Date _____ Co. name _____ Signed _____

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____ and employed by _____

of _____ have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____ not included in the certificate of shop inspection, have been inspected by me and that, to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with ASME Code, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____ psi. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage of a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commission No. _____